

August 21, 2025

PART 1 - ADDENDUM

1.1 TITLE

- .1 This Addendum shall be known as:

Addendum 2
TFM-031-25 – CORE SCIENCE BUILDING
CERC FIT UP, LEVEL 5 – PAVILION C
- .2 The Date of the Addendum is Thursday, August 21, 2025

1.2 PRECEDENCE

- .1 This Addendum to the bid documents is effective immediately.
- .2 This Addendum shall form an integral part of the original bid documents and is to be read in conjunction therewith.
- .3 The Addendum shall take precedence over previously issued bid documents with which it may prove to be at variance.

1.3 GENERAL

- .1 The General Conditions shall govern all phases of the Work covered by this Addendum.
- .2 Acknowledge receipt of this addendum in the Tender and Acceptance form.

1.4 PURPOSE

- .1 The purpose of the Addendum is to inform bidders of the changes, deletions and additions to be added to the bid documents.

1.5 CHANGES IN GENERAL

- .1 No general changes.

1.6 CHANGES TO SPECIFICATION

- .1 **Specification Section 08 50 00 Windows**
 - .1 **Remove** Article 2.1.4 in its entirety.
 - .2 **Replace** with the following:
 - 2.1.4 Frames:
 - .1 Profile Size: to wrap wall type as scheduled.
 - .2 Colour: clear anodized to match frame in the same area on

August 21, 2025

level 4.

- .2 Specification Section 08 50 00 Windows
 - .1 **Remove** Article 2.1.5 in its entirety.
 - .2 **Replace** with the following:
 - 2.1.5 Standard of Acceptance:
 - .1 PC350, single glazing by PC350 Inc. 130 Noal Court, Markham, ON. L3R 2V7, Canada. PC350.com, (866)-633-0233.

1.7 CHANGES TO DRAWINGS

- .1 **A-2.1 – New Floor Plan**
 - .1 Add:
 - .1 General Notes: Floor Plan
 - .1 5. The height from floor slab to u/s of deck is +/- 5110mm.
- .2 **E301 – Revised Lighting and Fire Alarm Systems Floor Plan – Level 5, Pav-C**
 - .1 In Room 5104A, replace the 4 – Type L50 light fixtures with 4 – Type L10 light fixtures in the same locations. Circuiting and switching controls to remain as indicated. In this room, contractor shall supply and install chains, hanging materials, and unistrut, to support the installation of this light fixture type in an open ceiling space.

END OF ADDENDUM #2

August 11, 2025

PART 1 - ADDENDUM

1.1 TITLE

- .1 This Addendum shall be known as:

Addendum 1
TFM-031-25 – CORE SCIENCES BUILDING
CERC FIT UP, LEVEL 5 – PAVILION C

- .2 The Date of the Addendum is **Monday, August 11, 2025**

1.2 PRECEDENCE

- .1 This amendment to the bid documents is effective immediately.
- .2 This Addendum shall form an integral part of the original bid documents and is to be read in conjunction therewith.
- .3 The Addendum shall take precedence over previously issued bid documents with which it may prove to be at variance.

1.3 GENERAL

- .1 The General Conditions shall govern all phases of the Work covered by this Addendum.
- .2 Acknowledge receipt of this addendum in the Tender and Acceptance form.

1.4 PURPOSE

- .1 The purpose of the Addendum is to inform bidders of the changes, deletions and additions to be added to the bid documents.

1.5 CHANGES IN GENERAL

- .1 **A Non-mandatory Site Visit to be held Wednesday, August 13, 2025 at 1:30pm.
Location 5th floor elevator lobby, pavilion C, Core Sciences Building.**

1.6 CHANGES TO SPECIFICATION

- .1 No changes to Specification. [Click here to enter text.](#)

1.7 CHANGES TO DRAWINGS

- .1 No changes to drawing. [Click here to enter text.](#)

END OF ADDENDUM