Memorial University Water Quality Testing Results
The maximum allowable concentration for lead is 5 micrograms per litre, as published by Health Canada
2024 Sampling Results

			Initial Sample			Re-Sample 1			Re-Sample 2	
Building	**Location**	Date Sampled	**First draw (µg/L)**	**5 Minute Sample (µg/L)**	**Date Sampled**	**First Draw (µg/L)**	**5 Minute Sample (µg/L)**	**Date Sampled**		**Comments**
Feild Hall	GH-3010	Nov 26 2024	2.5	1						
Spencer	SP-4014	Nov 26 2024	15.6	11.4						Filtered location
Coughlan College	CL-1007	Nov 26 2024	18.9	6.5						On bottled water
Business	BN-4015	Nov 26 2024	1.5	2.8						
C-Core	K-2012	Nov 26 2024	1.5	1						
Baltimore	BM-2011	Nov 27 2024	0.9	<0.5						
Juniper House	BP-2001	Nov 27 2024	1	1.2						
Mt Scio	MS-1020	Nov 27 2024	2.2	0.9						
Signal Hill Campus	B-5100	Nov 27 2024	<0.5	<0.5						
Cabot	CT-103	Nov 27 2024	<0.5	1.5						
Education	ED-4037	Dec 10 2024	2.5	0.8						
Education	ED-2030B	Dec 10 2024	2.6	1.4						
Physical Education	PE-2100	Dec 10 2024	9	6.2	10-Jan-25	3.9	<0.5			Cleaned and re-sampled
Global Learning Centre	CA-2C02	Dec 10 2024	2.8	1.3						
Shiwak Hall	WX-3015	Dec 11 2024	1.5	<0.5						
Cluett Hall	EX-2015	Dec 112024	4.9	<0.5						
Hatcher	HA-106	Dec 11 2024	0.7	<0.5						
Doyle	DO-109	Dec 11 2024	0.8	<0.5						
Blank		Dec 11 2024	<0.5	<0.5						
Bruneau	IIC-1033A	Dec 3 2024	1.9	1.8						
Arts and Administration	A-4049F	Dec 3 2024	1.5	<0.5						
Chemistry	C-2012B	Dec 4 2024	5.4	1.6						
Science	SN-3125	Dec 4 2024	8.9	2.6						Cleaned aerator
Henrietta Harvey	HH-2047	Dec 4 2024	3.2	0.9						
Core Science Facility	CSF-4301	Dec 3 2024	8.6	<0.5						
University Centre	UC-2002D	Dec 3 2024	1.1	<0.5						
Queen Elizabeth II Library	L-1021	Dec 3 2024	6	2.3						
Blank			1	1						